

Performance Chart



Product: SHAPED WINDOW

Series: 510 GOPI

Test Type:

Air infiltration (ASTM E 283)

Test Size:

Results:

0.03 CFM/F+ @ 6.24 PSF

Water Resistance (ASTME 547/E 331)

20 PSF

Uniform Static Loadtest (Design Load)
(ASTM-E 330)

37 X 74 (7/16 ANN PVB)
37 X 74 (7/16 ANN UVEKOL)

POSITIVE 71 PSF NEGATIVE 71 PSF
POSITIVE 71 PSF NEGATIVE 71 PSF

Cyclic Design Load Test after Missile Impact
in Accordance to Miami - Dade County
(TAS 201 & 203)

37 X 74 (7/16 ANN PVB)
37 X 74 (7/16 ANN UVEKOL)

POSITIVE 71 PSF NEGATIVE 71 PSF
POSITIVE 71 PSF NEGATIVE 71 PSF

Forced Entry test AAMA 1302.5-1976
Paragraph 3.1.1 Test A-3.15 Test G

PASSED

Operating Force Opening

N/A

Operating Force Closing

N/A